

Smoke Alarm Maintenance Checklist/Sign-Off
Small Buildings (1- 5 units)

ADDRESS: _____

SUITE: _____

DATE: _____

ANNUAL TEST & MAINTENANCE

YES

NO

- | |
|--|
| <ol style="list-style-type: none">1. Smoke alarm is securely fastened to ceiling2. No visible signs of damage or being painted3. Battery has been replaced and secure4. Smoke alarm has been tested and alarm sounded5. Battery type smoke alarm |
|--|

AUTHORIZATION:

Test Conducted by:

Print Name	Signature
------------	-----------

Tenant Name:

Print Name	Signature
------------	-----------

Ontario Fire Code

2.13.2.3.(2)

Smoke alarms shall be installed between each sleeping area and the remainder of the dwelling unit, and where the sleeping areas are served by hallways, the smoke alarms shall be installed in the hallways.

6.3.3.2.

Smoke alarms shall be maintained in operating condition by the owner.

6.3.3.4.

No person shall intentionally disable a smoke alarm so as to make it inoperable.